





New Paradigm: Architect/ Engineer
Collaborative Energy Models

PAYETTE


2030 COMMITMENT – ENERGY REDUCTION GOALS



TYPICAL ARCHITECT – ENGINEER WORKFLOW




COLLABORATIVE ARCHITECT – ENGINEER WORKFLOW



FEEDBACK LOOPS


NEW INTEGRATED TOOLKIT - LADYBUG



MUSEUM



INTEGRATED PERFORMANCE MODELLING



MECHANICAL SYSTEMS – RADIANT FLOORS

Central Plant Heating

Conventional Boiler

Condensing Boiler

Geothermal Heat Pump

Central Plant Cooling

Packaged/Dx Units

Air-cooled Chiller

Water-cooled Chiller

River Water Heat Exchanger


Geothermal Heat Pump

Distribution/Terminal

Conventional VAV

Dedicated Outdoor Air
System with Fan Coils

Dedicated Outdoor Air
System with Radiant Floors



PARAMETRIC STUDIES: RADIANT SLAB


INPUTS:

- Top Slab Thickness (3")
- Pipe Spacing (6", 9", 12", 18")
- Water Temperature (50F, 51F, 52F, 53F, 54F, 55F, 56F, 57F, 58F, 59F, 60F)
- Solar Load (0 btu/sf, 10 btu/sf, 20 btu/sf, 30 btu/sf, 40 btu/sf, 50 btu/sf, 60 btu/sf, 70 btu/sf, 80 btu/sf, 90 btu/sf, 100 btu/sf)


= 484 SIMULATIONS

OUTPUTS:

- Total Heat Removed
- Radiant Heat Removed
- Convective Heat Removed
- Degrees from Condensing




RADIANT SLAB STUDIES




ITERATIVE RADIANT SLAB STUDIES


Parametric THERM Model




Parametric THERM Radiant Slab




Parametric Radiant Slab - Heating



Parametric Radiant Slab - Cooling



PEAK SOLAR LOADS ON SLAB




CURRENT DESIGN

SHGC: 0.35

Frit: none

Shading: none



Maximum Solar Radiation:

224 BTU/sf on October 30th at 11 am


EXCEEDS TARGET

OPTION 1

SHGC: 0.35

Frit: 50% (equivalent SHGC: 0.175)

Shading: none



Maximum Solar Radiation:

99 BTU/sf on October 17th at 11 am


EXCEEDS TARGET

OPTION 2

SHGC: 0.35

Frit: 65% (equivalent SHGC: 0.1225)

Shading: none




Maximum Solar Radiation:

65 BTU/sf on September 30th at 11 am

MEETS TARGET

ATRIUM COMFORT

Hottest Week
 Average peak outdoor operative temperature = 90 °F
 Outdoor Air temperature = 80 °F
 2.67 ft/s is approx acceptable highest air speed



NATURAL VENTILATION

No Openings or Smoke Exhaust

With Smoke Exhaust at 2.67 ft/s
 ACH 7.4


With Smoke Exhaust at 1 ft/s
 ACH 2.8

With Smoke Exhaust at 0.5 ft/s
 ACH 1.4

Only Buoyancy, velocity at 1.7 ft/s
 ACH 4.7

AIR
 TEMPERATURE
 (DRY BULB)


OPERATIVE
 TEMPERATURE



HOSPITAL PATIENT ROOM







OPTIMIZING MASSING | SOLAR BENEFIT STUDY



NET RADIATION (kWh/m²)

Beneficial Radiation

Harmful Radiation



6%

Reduction in patient room energy

15%

Reduction in peak solar load

54%

Decrease in direct solar radiation

PARAMETRIC EARLY ENERGY MODEL


INPUTS:

- Glazing Ratio (40%, 50%, 60%, 70%)
- R-Value (spandrel, solid)
- Glazing U-Value (0.4, 0.25)
- Exterior Vertical Fins (0", 15", 30")
- Orientation
- HVAC Type (VAV, Hydronic)

= 576 SIMULATIONS


OUTPUTS:

- EUI
- Peak Cooling
- Peak Heating
- HVAC Size




PARAMETRIC EARLY ENERGY MODEL


Design Explorer



PARAMETRIC EARLY ENERGY MODEL




THE IMPACT OF PARAMETERS







PEAK LOADS & ENVELOPES

LIMITATIONS OF CHILLED BEAMS




PEAK LOADS & ENVELOPES


Solar Glazing Conduction Opaque Conduction Infiltration Equipment Lighting People



ITERATING THROUGH DESIGN OPTIONS



ENERGY SAVINGS FOR OPTIMIZED DESIGN



SUMMARY OF LESSONS LEARNED

- Communication
 - Internal
 - With consultants
 - With Owner
- Iterative Process
- Specialize in what you know best - right tools for right people on the team
- Focus efforts on critical components

